

Brimfield Board of Health Meeting of April 4th, 2023

Board Members Present: Chair R. Costa, K. Marino, M. Polack and M. Koprowski
Present: Administrative Assistant Michelle Metcalf, Health Agent Jamie Terry

The meeting was called to order at 6:33 PM

COVID-19 –Update

- The board discussed and decided to remove old business from the agenda. If anything new comes up to discuss they will add it back to the agenda.

WasteZero- Contract Extension

- Board discussed that the extension of the contract in the second year has an increase significantly higher than the first year. The board has looked at other companies in the past, but the quality of the bags was very low. K. Marino made a motion to approve the contract extension. Seconded by M. Polack. Vote K. Marino (**Yes**), M. Polack (**Yes**), M. Koprowski (**Yes**), R. Costa (**Yes**). The vote was unanimous.

2023 Student Scholarship

- The board reviewed the two applicants that applied for the scholarship. M. Koprwski made a motion to give the two students each \$750.00 from the \$1,500.00 from the Republic scholarship fund. Seconded by M. Polack. Vote M. Koprowski (**Yes**), M. Polack, (**Yes**), K. Marino (**Yes**), R. Costa (**Yes**). The vote was unanimous.
he board

8 Wood Hill Rd- Well

- Well application and variance request came in for 8 Wood Hill Rd. Connecticut Valley Well requested 50ft to leach field. If the request is approved, then the septic system will automatically fail according to Title 5 regulations. K. Marino made a motion to deny various requests due to the septic system automatically failing with Title 5 regulations. The vote was seconded by M. Koprwski. Vote as K. Marino (**Yes**), M. Koprwski (**Yes**), M. Polack (**Yes**) R. Costa (**Yes**). Vote was unanimous
off-set

10 John Haley- Septic Repair

- The engineer is Lorri McCool for a repair for a 3 bedroom. The property needs a 4ft to 3 ft ground water offset. M. Polack made a motion to approve a 4ft to 3 ft groundwater offset. Seconded by M. Koprwski. Vote as M. Polack (**Yes**), M. Koprwski (**Yes**), K. Marino (**Yes**), R. Costa (**Yes**). The vote was unanimous.

279 Little Alum- Septic Repair

- The engineer is Lorri McCool. For a 2-bedroom repair. Property is deed restricted. No various No vote needed.

41 Seventh Street- Septic Repair

- Engineer is DC engineering. Health Agent J. Terry has been requested to do another deep hole test because the property owner is looking to move the septic system. No various No vote is needed.

99 Haynes Hill- Septic Repair

- Engineer is Green Hill for a 4-bedroom repair. The property needs a 4ft to 3ft ground water offset. M.Polack made a motion to approve a 4ft to 3ft ground water offset. Seconded by K. Marino. Vote as M. Polack (**Yes**), K.Marino (**Yes**), M.Koprwski (**Yes**),R.Costa (**Yes**). The vote was unanimous.

Minutes February 7th ,2023

- The Board tabled the minutes till the next meeting for more time to review.

The meeting adjourned at 7:08 PM

Respectfully submitted,

Michelle Metcalf
Administrative Assistant